



Declaration of conformity

| For the following equipment : | | | | |
|--|------------------------------|----------------|-------------|--------------------------------------|
| Product Name: Switching Power Supply | | | | |
| Model Designation: GST40Ax, GST60Ax (x=05,07,09,12,15,18,24,48) | | | | |
| is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied: | | | | |
| RoHS Directive (2011/65/EU)、(EU)2015/863 | | | | |
| Low Voltage Directive (2014/35/EU): | | | | |
| EN 62368-1:2014+A11 | TUV certificate No : S | | | S 50422026 |
| Electromagnetic Compatibility Directive (2014/30/EU): | | | | |
| EMI (Electro-Magnetic Interference) Conducted emission / Radiated emission EN55032:2015 | | | | Class B |
| Harmonic current | EN61000-3-2:2014 | | | |
| Voltage flicker | EN61000-3-3:2013 | | | |
| EMS (Electro-Magnetic Se | usceptibility) | | | |
| EN55024:2010+A1:2015 | | | | |
| ESD air | EN61000-4-2:2009 | | Level 4 | 15KV |
| ESD contact | EN61000-4-2:2009 | | Level 4 | 8KV |
| RF field susceptibility | EN61000-4-3:2006+A1:2008 | 3+A2:2010 | Level 2 | 3V/m |
| EFT bursts | EN61000-4-4:2012 | | Level 2 | 1KV/5KHz |
| Surge susceptibility | EN61000-4-5:2014 | | Level 3 | 1KV/Line-Line |
| Surge susceptibility | EN61000-4-5:2014 | | Level 3 | 2KV/Line-Earth |
| Conducted susceptibility | EN61000-4-6:2014 | | Level 2 | 3V |
| Magnetic field immunity | EN61000-4-8:2010 | | Level 2 | 3A/m |
| Voltage dip, interruption | EN61000-4-11:2004 >95% dip (| 0.5 periods 30 | % dip 25 pe | riods >95% interruptions 250 periods |
| Note: The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete system, the final equipment manufacturers must re-qualify EMC Directive on the complete system again. For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File). | | | | |
| Energy-Related Products Directive (2009/125/EC): | | | | |
| Ecodesign requirements for no-load condition electric power consumption and average active efficiency of external power supplies EC No.278/2009 | | | | |
| This Declaration is effective from serial number EB8xxxxxxx | | | | |
| Person responsible for marking this declaration : | | | | |
| MEAN WELL Enterprises Co., Ltd. (Manufacturer Name) | | | | |
| No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan (Manufacturer Address) | | | | |
| Johnny Huang/ Manager, Certification Center: (Name / Position) Alex Tsai/Director, Marketing Department: (Name / Position) (Signature) (Signature) | | | | |
| Taiwan | Jul. 22nd, 2019 | | | |

(Date)

(Place)